

Introduction to Biodiesel



Renewable Fuels

Biodiesel is a diesel fuel produced by chemical refining of vegetable oils into “fatty acid methyl esters,” or FAME. Glycerin is removed in the refining process, lowering oil viscosity to match diesel fuel. Pure biodiesel is most often added to diesel fuel in a 2, 5, or 20% blend, and referred to as B2, B5, or B20 respectively.

Other renewable “biofuels” are raw oils or recycled greases that have not been transformed into biodiesel. These products require extra heat, filtration, and other vehicle modifications to burn in diesel engines.

Challenges and Solutions

Racor fuel filters and heaters are uniquely suited for filtering and conditioning biodiesel and biofuels for use in diesel engines.

Biodiesel tends to dissolve natural fuel “tar” deposit coating the inside of diesel tanks, piping, and hoses. Dissolved deposits are carried to fuel filters, causing shortened fuel filter life. Most biodiesels have a low “interfacial tension.” This means that water easily disperses and dissolves in fuel. Low interfacial tension greatly reduces water separation efficiency for all types of water separators and coalescers. Removal of water from a fuel system is necessary for proper engine performance.

Racor recommends using the largest filter practical for the application. A larger filter adds more filtration media surface area, which lowers flow velocity going to each square inch of media. This extends filter life and increases water removal efficiency. When specifying a new biodiesel fuel system, de-rate fuel filter flow by 50% and install on the vacuum (suction) side of any pumps, where possible.

Pure biodiesel has high cloud and pour points, necessitating the use of electric and/or coolant heaters in cold weather. Higher percentage blends (B20) act more like standard diesel fuel, but some lower fuel blends have been known to cause problems. Other biofuels of raw oil or recycled grease have high viscosity as well as cloud and pour points, and must be heated to high temperatures to be used.

Racor recommends using at least 200 watts of thermostatically controlled electric heating in the head and/or filter bowl to help avoid biofuel waxing and gelling. Pour point suppressants and biocides are necessary for reliable operation. A coolant heat exchanger is required to heat fuel in extreme cold weather conditions.

Biodiesel is known to attack certain synthetic rubber compounds, making them swell and soften, or shrink and harden. Racor uses very high quality synthetic rubber compounds that perform equally well in biodiesel as in standard diesel. Seals subject to biodiesel exposure are generally replaced at the same time as replacement filters. Racor uses all materials compatible with up to 20% biodiesel blend. Above 20% may require material changes to dynamic seals that are not normally replaced at filter change-outs.



Engineering Leadership

Racor has participated in several biodiesel filtration field tests with major OEMs. We are actively participating in industry wide research and development on biodiesel fuel filtration and water separation challenges. Development of technology to support the use of all biofuels is on-going.











Biodiesel and Biofuel Filtration

Specify The Following:

- Large primary and secondary filters at 50% of their rated flow.
- High quality, corrosion resistant materials in construction.
- High quality, synthetic rubber compounds for seals and hoses.
- Efficient coolant and/or electric heating.
- Fuel source with high efficiency fuel dispensing.

Fuel Filtration Systems

Recommended for Biodiesel and Biofuels

Fuel Dispensing	Electric Heated Primary Filtration	Coolant Heated Primary Filtration	Electric Heated Secondary Filtration	Coolant and Electric Heaters
FBO 	6120R1230 	390RC1230 	690R122 	320HTR4 
RVFS/RVMF 	1000FH1230 	525 	6120R122 	Nomad 14287 

Notes: Marine rated versions are available-consult factory. Also available-Thermoline Heaters, 300 and 500 watt, 12 and 24 volt.



Questions? Contact Technical Support:
800 344 3286 or 209 521 7860 ext. 7555
e-mail: racortech@parker.com

PROSEP FILTER SYSTEMS LTD
Unit G19
River Bank Way
Lowfields Business Park
Elland
West Yorkshire
HX5 9DN

Tel: 01422 377367

Fax: 01422 377369

Email: enquiries@prosep.co.uk

www.prosep.co.uk

Map and Directions to Prosep Filters Limited



Leave M62 at Junction 24.

At roundabout adjacent to Cedar Court Hotel take 2nd exit onto dual carriageway (A629), signposted Halifax.

Take 1st exit slip road.

At roundabout at end of sliproad, take 3rd exit off.

This is the entrance to Lowfields Business Park.

Proceed straight over 1st roundabout.

At next roundabout take 2nd exit onto River Bank Way - Prosep Filters can be found on the left after the S-bend.

[Link to Google Maps](#)